

Project: Capital Area Transportation Authority (CATA) Fluid-Applied Roof Restoration

Date: May 14, 2024

File No: 75820019

To: Capital Area Transportation Authority (CATA) Norm VanAlstine, Nicole Wilson
Progressive AE - Chris Sholl, Seth Horton

All Plan Holders

AD1-1 NOTICE

- A. This Addendum to the specifications and drawings for the above-captioned project adds to or supersedes all contrary or conflicting information in specifications and drawings which is amended in the following paragraphs. This Addendum is to become part of bidding documents as originally issued.
- B. Each trade shall review the entire Addendum, including work of other trades, for revisions or clarifications regarding their own work.
- C. This Addendum includes drawing herein numbered A102, revised and dated May 14, 2014.

AD1-2 ARCHITECTURAL WORK (EM)

A. SPECIFICATION ITEMS

- 1. **Section 00 4325 Substitution Requests** (Not Reissued):
 - a. See attached product Substitution Request – rejected.

B. DRAWING ITEMS

- 1. **Drawing A102** (Reissued):
 - a. Cut and patch membrane to remove excess material along northeast roof line.
 - b. Remove and replace membrane areas indicated that extend over fascia due to membrane deterioration.
 - c. Clarify extent of ‘cupped’ insulation to be replaced.
 - d. Provide removal of existing curb and replace with new decking.
 - e. Re-establish roof drain concealed under existing membrane.

SECTION 00 4325 SUBSTITUTION REQUEST FORM - DURING PROCUREMENT

PROJECT: CATA FLUID-APPLIED ROOF RESTORATION

PROJECT NO. : 75820019

To: Progressive AE; Attention: *Chris Sholl*; *csholl@weareprogressive.com*

Re: CATA Fluid Applied Roof Restoration - Lansing, MI From: Dann Moesta on behalf of Sika Roofing and Waterproofing Date: 04/30/2024

DESCRIPTION:

Specification Title: CATA Fluid Applied Roof Restoration

Section No.: 2.04 Page: 07 0150.74 - 4 A Paragraphs 1-5

Article/Paragraph: &B

Proposed Substitution: Sikalastic RoofPro System; (Sikalastic 641; Fleece/Reemat Reinforcement; SA Joint

Manufacturer: Tape; EP Primer) || SIKA Roofing and Waterproofing

Trade Name: Sikalastic RoofPro

Model No.: NA

Web Site: tinyurl.com/4y8fnf4w

SUPPORTING DATA ATTACHED:

- Attached data to include product description, specifications, drawings, photographs, and performance and test data adequate for evaluation of the request; applicable portions of the data are to be clearly identified.

- Attached data to also includes a description of changes to the Contract Documents that the proposed substitution will require for its proper installation.

() Drawings (X) Product Data () Samples () Tests () Reports ()

THE UNDERSIGNED CERTIFIES:

- Proposed substitution has been fully investigated and determined to be equal or superior in all respects to specified product.

- Same warranty will be furnished for proposed substitution as for specified product.

- Same maintenance service and source of replacement parts, as applicable, is available.

- Proposed substitution will have no adverse effect on other trades and will not affect or delay progress schedule.

- Proposed substitution does not affect dimensions and functional clearances.

- Payment will be made for changes to building design, including A/E design, detailing, and construction costs caused by the substitution.

Signed by: (printed)

Daniel R Moesta II

(signature)

Daniel R. Moesta

Address: 12283 Twyckenham Dr. Fisher, IN 46037

Email: dann@misc.construction

A/E'S REVIEW AND ACTION:

() Substitution approved - Make submittals in accordance with Specification Section 01 6000 - Product Requirements, Substitution Procedures.

() Substitution approved as noted - Make submittals in accordance with Specification Section 01 6000, Substitution Procedures.

(X) Substitution rejected - Use specified materials.

() Substitution request received too late - Use specified materials.

Remarks Materials do not comply with specification. Sika is a single component product compared to the Tremco Alpha Bio which is a two-component system.

SECTION 00 4325 SUBSTITUTION REQUEST FORM - DURING PROCUREMENT

Signed by: _____ *Christopher T. Sholl* Digitally signed by Christopher T. Sholl Date: 2024.05.02 09:08:35-04'00' _____

