

ADDENDUM NO. 2
February 3, 2014

RE: **Propane Fueling Station**
Capital Area Transportation Authority
Lansing, Michigan

To: All Bidders and others to whom Plans and Specifications for the above referenced Project have been issued.

The items included in this Addendum are to become a part of the original Drawings and Project Manual as if included therein. Only these items are to be altered. The remainder of the original Drawings and Project Manual remain valid in their entirety.

The bidder shall furnish a signed copy of this cover page with the submission of a bid.

Bidder's Signature of Addendum Acknowledgement

Date

PROJECT MANUAL

<u>Section</u>	<u>Article</u>	<u>Action</u>
<u>Division 01 – General Requirements</u>		
01230	3.1 A 1	Add “Continue conduit from electrical contractor (by others) terminated at edge of generator foundation into generator housing.

ADDITIONAL CLARIFICATIONS

1. Direct burial of piping is acceptable. Provide piping that is shielded.
2. Contractor shall furnish all wiring, conduit, trenching, labor, material and other work as required to connect propane dispensing system to either the 480V/50A sub panel furnished in the backup generator by others (alternate generator location) or to Power Panel DP2 located in the Maintenance Bay on the west side of the main switchgear room (base bid generator location).

END OF ADDENDUM

M:\PROJ\0941\6302\Task D-21 Propane Fueling Station\DOCS\Bidding\AD 2\Addendum-2.docx