

**ADDENDUM # 1 TRANTER OFFICE CCTV CAMERA EXPANSION RFP #2013-103
CAPITAL AREA TRANSPORTATION AUTHORITY**

TRANTER OFFICE CCTV CAMERA EXPANSION

Vendor Questions and Answers

Each question received from interested vendors in regard to the above Request for Proposal (RFP) is consecutively numbered 1-5 below and labeled "Q". Below each question is CATA's official corresponding answer labeled "A" and written in italics.

This Addendum is enclosed within this correspondence, and is also available on the CATA website at www.cata.org, located under the heading "Doing Business With CATA".

1. Q: Please state the server specifications.

A: HP Proliant DL380e Gen 8 server. Two 4 core 2.53 GHz processors, 16gb ram, 12tb storage expandable to 16tb.

2. Q: Is it OK to run cable through the roof membrane?

A: No, any mounting holes or cable paths will be through the side of the building.

3. Q: Is a bid bond required and what is the percentage?

A: Yes a bid bond is required at 5% of the bid.

4. Q: Will CATA provide servers and storage?

A: Yes, all cameras reside on the CATA network.

5. Q: Is CATA open to changing operating system?

A: Yes, as a proposal alternate only.

Please also review:

Attachment A – Large Tranter Print

Attachment B – Tranter Camera Listing

Attachment C – Tranter North Lot Conduit

Attachment D - Tranter Licenses

Attachment E - Pre-Bid Sign-In Sheets

This Addendum is enclosed within this correspondence, and is also available on the CATA website at www.cata.org, located under the heading "Doing Business With CATA".