

**ADDENDUM # 1 TO CATA RFQ #2012-301  
CAPITAL AREA TRANSPORTATION AUTHORITY  
FIRE ALARM SERVICES**

Attached is a Question received from an interested vendor in regard to the above Request for Quote (RFQ). Below is CATA's official answer to this question.

**Q. We are interested in bidding for the inspection services detailed on the Builders Exchange for the above listed opportunity. In order to quote properly we need to know the brand and model numbers for the existing equipment. Can you provide us with the information or at least the contact information of who to reach out to for the answers we need?**

A. All Equipment is Siemens

Model #

Smokes/Duct HFP-11

Horn/Strobes ZH-MC-R

Manual Pulls HMS-D

Please also refer to the information listed within the Fire Alarm Monitoring and Inspection Specification included with this RFQ which is available on the CATA website at [www.cata.org](http://www.cata.org), and located under the heading "Doing Business With CATA".