

**ADDENDUM # 2 TO CATA RFQ #2012-301
CAPITAL AREA TRANSPORTATION AUTHORITY
FIRE ALARM SERVICES**

Attached are Questions received from an interested vendor in regard to the above Request for Quote (RFQ). Below are CATA's official answers to the questions.

Questions:

- 1) Do you want separate pricing for the Corporate Office and the Transportation Center?**
- 2) If yes to question one, is there a specific place that you want those prices on the specification? I don't see a specific line to insert the price.**
- 3) How many of the smoke detectors and duct detectors at the Corporate Office are above 12' in height and will require the lift to perform the inspection?**
- 4) Is this considered a construction contract...Will a bid bond and performance and payment bonds be required (Term & Conditions Items B 15 & 16)?**

Answers:

- 1. Yes.**
- 2. Please separate the pricing for the Administrative Office and the CATA Transportation Center and provide a grand total dollar amount which includes both facilities. You may use an additional sheet to detail your pricing information or post this information directly on the front of one of the pages of your bid response.**
- 3. Over 80% of the smoke detectors and duct detectors located at the CATA Administrative Office require a lift to perform an inspection.**
- 4. This is not a construction contract, it is a service contract.**

Please also refer to the information listed within the Fire Alarm Monitoring and Inspection Specification included with this RFQ which is available on the CATA website at www.cata.org, and located under the heading "Doing Business With CATA".