

**ADDENDUM # 4 TO CATA RFQ #2012-301
CAPITAL AREA TRANSPORTATION AUTHORITY
FIRE ALARM SERVICES**

Listed below are additional specifications in regard to the above Request for Quote (RFQ).

Office and Storage Area FM200 Suppression Inspection (2) – Semi Annual

- Perform a functional test on all fire alarm equipment listed herein.
- Sensitivity testing on a two year cycle.
- Visually check pressure gauges and record readings.
- Visually check agent level and record measurement.
 - (2) Notifier Fire Alarm Control Panel
 - (13) Manual Pull Stations
 - (13) Abort Stations
 - (33) Smoke Detectors
 - (15) Horn Strobes

Please also refer to the information listed within the Fire Alarm Monitoring and Inspection Specification included with this RFQ which is available on the CATA website at www.cata.org, and located under the heading “Doing Business With CATA”.